



# Power Market Transformation

and **Power Quality** impact of Prosumer on Distribution

**Smart Grid**



**Mr. Wanchalerm Patanacharoenwong**

Engineer L.5 of Power Quality Analysis Section

**Miss Panaya Sudta**

Assistant Chief of Power Quality Analysis Section  
CUSTOMER SERVICE DIVISION  
PEA Area 3 (North) Loburi Province

# Power Market Transformation and Power Quality impact of Prosumer on Distribution Smart Grid

---



## AGENDA

- ❖ Introduction to PEA Smart grid Roadmap
- ❖ Transformation of Power Section
- ❖ Third Party Access Framework (in case prosumer)
- ❖ Challenge in Changing Distribution network
- ❖ Reliability & Power Quality Challenge



# PEA Smart grid Roadmap



## Smart Energy

- Electricity networks in 4 cities automated system.
- Unmanned substation
- Microgrids
- Energy Storage / Solar Rooftop
- Network supports of DG
- The integration of Enterprise System
- Mobile Workforce in 4 cities

- Optimal Asset management
- Complete of MWM
- Completion of unmanned substation
- Expand fully automated network covering major cities across the country
- **The penetration of renewable energy sources and energy storage in communities**

- Automated electricity networks nationwide/self-healing features enabled
- **Smart community network integrated with a large renewable energy resources**
- Perfect cyber security system
- The balanced and forecast system production corresponds to energy utilization
- **Virtual power plants created**

## Smart Life

- Advanced Metering Infrastructure (AMI) in 26 municipalities of PEA service area
- Demand response management

- AMI development completion
- Energy management completion in all large/medium cities
- The system provides power usage information via the internet
- **Domestic consumers can produce their own electricity; surpluses can be sold to utility**
- **Home/building energy management automation reduces electricity bills**

- **Power consumers can buy or sell electricity in real time**
- Users can choose to buy electricity from different supplies
- Optimal Energy management

## Smart Community


- Public charging station


- The extensive use of electric transportation
- The penetration of intelligent public street and community lighting in communities
- Bundled services with other utilities (common billing etc.)

- **Intelligent electric vehicle charging to reduce peak demand**
- Two ways power supply of electric vehicles (vehicle to grid –V2G)




# Structure of Power Market in Thailand






A vertically integrated power system



Disintegration of the vertically integrated structure of electric power companies

## THE ELECTRICITY MARKET



Source: The Structure of electricity market by Mikael Amelin

KTH Royal Institute of Technology in Stockholm

# Challenges: Changing distribution networks



Increasing penetration of DERs (e.g., PVs, EVs, HPs, BES) connected to medium and low voltage distribution networks.

## Problems

Network congestion  
Voltage variations (over and under)

## Solutions

New investment in cables/transformers:  
Expensive!


Improved operation:

- Technical: Coordinated operation of OLTCs, capacitor banks, storage, flexibilities from DERs and demand responses.
- Local market for flexibilities/grid services; grid tariffs


Local Flexibility Services  
DER Hosting Capacity (Planning)  
Operating Envelope (Operation)

# Problems formulations for prosumer management

## Analyst and cluster the load pattern



# Details of SPP and VSPP COD in PEAN3



Type	Voltage	Amount (case)	Capacity (MW)
VSPP (EGAT)	22 kV	5	31.00
SPP (EGAT)	115 kV	12	670.00
VSPP (PEA)+PVRT	22 kV	73	289.02
- PVRT	22 kV	9	6.37
Solar PV Rooftop	220/380 V	251	1.88
<b>Sum</b>		<b>341</b>	<b>991.90</b>

← 14/03/2559



บริษัท เค.จี. เอนเนอร์จี

เบอร์โทรศัพท์  
081-8036600, 02-9514455, 02-9515535

เลขที่สัญญา  
PV-PEA-N3-533/2558

กำลังผลิตติดตั้งจริง (kW)  
10

สถานที่ติดตั้งแผง  
10 หมู่ที่ 3 ตำบลวังขอนขว้าง อำเภอโคกสำโรง จังหวัดลพบุรี

พิกัด  
15.027495, 100.686533

เลขที่หนังสือใบอนุญาต  
5505.3/1013


สถานะดำเนินการ  
COD แล้ว

พื้นที่ กฟผ.  
กฟผ.โคกสำโรง

PEA No หมอแปลง  
52-920619


ขนาดหม้อแปลง (kVA)  
100

หมายเหตุ  
\*







# The impact evaluation of SPP & VSPP

## EGAT Substation



Export 53.50 MWh Import 23.7 MWh

## (115 kV)



High level of MVar WIR 115 kV

MW\_IMP MW\_EXP MVAR\_IMP MVAR\_EXP

Loss in distribution system



# Power Quality Problem: Harmonic

**Harmonic** is a signal whose frequency is a multiple of the frequency of a reference signal




Harmonics are due to periodic distortion of the voltage or current waveform

The distortion comes from nonlinear devices, principally loads

Harmonic Sources

- Ferromagnetic devices-  
Transformers, motors
- Arcing devices-  
arc furnaces, fluorescent  
lighting


**Power converters: Prosumer Devices** Fundamental component




## Decomposition into Harmonic Components – Fourier series

$$v(t) = V_{dc} + \sum_{h=1}^{\infty} \sqrt{2}V_h \sin(h\omega_0 t + \theta_h)$$




$$i(t) = I_{dc} + \sum_{h=1}^{\infty} \sqrt{2}I_h \sin(h\omega_0 t + \delta_h)$$



## Harmonic Sources – 6-pulse rectifier e.g. Variable Speed Drives or Medium Frequency Furnaces



- $h = p m \pm 1$
- $h = 6 m \pm 1$
- $i_h = I_1/h^*$
- $\varphi \approx \alpha$




$h$ =harmonic;  $p$ =pulse number;  $m= 1,2,3, \dots$  ;  $f_N$ = system frequency ;




\* for smoothed d.c. only

$\varphi$  = phase displacement between current and voltage;  $\alpha$  = converters firing angle

## Harmonic Sources – 12-pulse rectifier e.g. Variable Speed Drives or Medium Frequency Furnaces



- $h = p m \pm 1$
- $h = 12 m \pm 1$
- $i_h = I_1/h^*$
- $\varphi \approx \alpha$



$h$ =harmonic;  $p$ =pulse number;  $m= 1,2,3, \dots$  ;  $f_N$ = system frequency;

\* for smoothed d.c. only







# Undesirable Effects of Harmonics in Power Systems

## Undesirable Effects of Harmonics

- Overheating resulting in need of derating of the equipment.
- Potential for problems with excessive ground currents (stray voltages, telephone interference, relay mis-operation) on systems with single phase loads.
- Capacitors for power factor correction and cable systems aggravate the problem by causing **resonances**.

## Are harmonic levels increasing?

- Changing system characteristics
  - More power factor correction
  - More cable
- Changing load
  - More harmonic generation
  - Less damping
- Other characteristics





# Harmonic Standard

## IEEE Standard 519-1992- Current Distortion Limits

Odd harmonics Distortion limits (% $I_L$ ) for individual customers

Base voltage Limit (kV)	$I_{SC}/I_L$	$h < 11$	$11 \leq h < 17$	$17 \leq h < 23$	$23 \leq h < 35$	$35 \leq h$
0.12 – 69	<20	4.0	2.0	1.5	0.6	0.3
	20-50	7.0	3.5	2.5	1.0	0.5
	50-100	10.0	4.5	4.0	1.5	0.7
	100-1000	12.0	5.5	5.0	2.0	1.0
	>1000	15.0	7.0	6.0	2.5	1.4
69.001 – 161	<20	2.0	1.0	0.75	0.3	0.15
	20-50	3.5	1.75	1.25	0.5	0.25
	50-100	5.0	2.25	2.0	0.75	0.35
	100-1000	6.0	2.75	2.5	1.0	0.5
	>1000	7.5	3.5	3.0	1.25	0.7
> 161	<50	2.0	1.0	0.75	0.3	0.15
	$\geq 50$	3.0	1.5	1.15	0.45	0.22

The limits applicable for normal conditions

For shorter periods (e.g. startup) limits may be exceeded by 50%

**Table 11-1 – Voltage Distortion Limits**

Bus Voltage at PCC	Individual Voltage Distortion (%)	Total Voltage Distortion THD (%)
69 kV and below	3.0	5.0
69.001 kV through 161 kV	1.5	2.5
161.001 kV and above	1.0	1.5

NOTE — High-voltage systems can have up to 2.0% THD where the cause is an HVDC terminal that will attenuate by the time it is tapped for a user.

Even harmonics are limited to 25% of the odd harmonic limits

The limits applicable for normal conditions

For shorter periods (e.g. startup) limits may be exceeded by 50%

Tables applicable for 6-pulse convertors

For higher pulse number (q), limits may be increased by a factor of  $\sqrt{q/6}$  provided non-characteristic harmonics are less than 25% of the specified limit.



# Current Distortion Limits at point of common coupling

PRC-PQG-01/1998: PEA's Regulation on the Power Network System

Interconnection code B.E.2559(2016)

Current Distortion Limits at point of common coupling

Base voltage limit PCC Voltage (kV)	MVAsc** Base	Current Distortion Limits (A rms)																	
		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
0.400	10	48	34	22	56	11	40	9	8	7	19	6	16	5	5	5	6	4	6
11 and 12	100	13	8	6	10	4	8	3	3	3	7	2	6	2	2	2	2	1	1
22, 24 and 33	500	11	7	5	9	4	6	3	2	2	6	2	5	2	1	1	2	1	1
69	500	8.5	6	4.3	7.3	3.3	4.9	2.3	1.6	1.6	4.9	1.6	4.3	1.6	1	1	1.6	1	1
115 and above	1,000	5	4	3	4	2	3	1	1	1	3	1	3	1	1	1	1	1	1

$$MVA_{SC1} \neq MVA_{SC-BASE}$$



$$I_h = \frac{I_{hp} \times MVA_{SC1}}{MVA_{SC-BASE}}$$

Where;

- $I_h$  = Harmonic Current (A) h order that is allowed to flow in the system when  $MVA_{sc} = MVA_{sc1}$
- $I_{hp}$  = Harmonic Current (A) h order in table 1
- $MVA_{sc1}$  = Minimum  $MVA_{sc}$  at PCC
- $MVA_{sc-Base}$  = Base  $MVA_{sc}$  for harmonic current from table 1


# Harmonic Analysis

กราฟเทียบกับเวลา



	ต่ำสุด	สูงสุด	เฉลี่ย	95%
AVrms	229.1	23830%	234.3	235.8
BVrms	225.8	235.5	231.6	233
CVrms	225.4	234.4	230.6	231.9
Alrms	25.73	791.2	186.7	225.7
Blrms	11.98	734.4	159.4	197.1
Clrms	10.79	828.3	165	201.3
AP(kW)	5.213	49.74	33.97	41.64
BP(kW)	1.22	44.73	28.47	36.45
CP(kW)	0.9054	42.47	26.4	33.93
AI HG03	1.834	18.95	14.49	15.98
BI HG03	0.5621	3.704	0.8732	1.328
CI HG03	1.052	16.23	12.45	14.04
AI HG05	0.6056	30.03	25.48	27.63
BI HG05	0.9695	24.91	21.09	22.73
CI HG05	0.5204	35.35	31.54	33.52
AI HG07	0.9075	20.19	17.7	18.85
BI HG07	0.7344	16.5	13.93	15
CI HG07	0.7152	22.77	20.1	21.37
AI HG09	0.5403	2.257	0.741	0.981
BI HG09	0.5693	1.361	0.8734	1.096
CI HG09	0.5433	3.514	0.9988	1.315
AI HG11	1.058	3.604	1.718	2.14
BI HG11	0.5512	4.571	3.715	4.129
CI HG11	0.6652	4.075	2.882	3.382
AI HG13	0.8249	4.108	2.799	3.234
BI HG13	0.4974	2.751	1.497	1.854
CI HG13	0.7068	3.852	2.471	2.777
AI HG17	0.6039	2.162	1.645	1.82
BI HG17	0.451	2.969	2.364	2.571
CI HG17	0.618	3.062	2.351	2.688
AI HG19	0.6282	1.548	0.9736	1.261
BI HG19	0.4346	1.246	0.5168	0.6135
CI HG19	0.4887	1.232	0.7574	0.9028


## Timeplot



— A Irms — B Irms — C Irms

	<i>Min</i>	<i>Max</i>	<i>Avg</i>	<i>95%</i>
<i>Alrms</i>	24.51	192.7	127.7	165.8
<i>Blrms</i>	27.78	204.4	135.3	174.7
<i>Clrms</i>	27.42	200.4	130.7	169.7

# Competitive Chart properties




Channels [DENSO INCOMING22KV 05-10-65]

- Basic Metering
- Adv. Metering
- Demand
- Adv. Energy
- Unbalance
- Flicker
- Distortion
- V Harmonics
- V Harmonic Groups (200ms)
- V Interharm. Groups (200ms)
- I Harmonics
- I Harmonic Groups (200ms)
- I Interharm. Groups (200ms)
- Adv. Unbalance
- Math channels
- Appearance
- Harmonics


V Interharm. Groups (200ms)
  I Harmonics
  I Harmonic Groups (200ms)
  I Interharm.

	A	B	C	D	
+ IHG00					Current 200ms Spectra by Harmonic Group index
+ IHG01					Current 200ms Spectra by Harmonic Group index
+ IHG02					Current 200ms Spectra by Harmonic Group index
+ IHG03					Current 200ms Spectra by Harmonic Group index
+ IHG04					Current 200ms Spectra by Harmonic Group index
+ IHG05	✓	✓	✓		Current 200ms Spectra by Harmonic Group index
+ IHG06					Current 200ms Spectra by Harmonic Group index
+ IHG07	✓	✓	✓		Current 200ms Spectra by Harmonic Group index
+ IHG08					Current 200ms Spectra by Harmonic Group index
+ IHG09					Current 200ms Spectra by Harmonic Group index
+ IHG10					Current 200ms Spectra by Harmonic Group index
+ IHG11	✓	✓	✓		Current 200ms Spectra by Harmonic Group index
+ IHG12					Current 200ms Spectra by Harmonic Group index
+ IHG13	✓	✓	✓		Current 200ms Spectra by Harmonic Group index
+ IHG14					Current 200ms Spectra by Harmonic Group index
+ IHG15					Current 200ms Spectra by Harmonic Group index
+ IHG16					Current 200ms Spectra by Harmonic Group index
+ IHG17	✓	✓	✓		Current 200ms Spectra by Harmonic Group index
+ IHG18					Current 200ms Spectra by Harmonic Group index
+ IHG19	✓	✓	✓		Current 200ms Spectra by Harmonic Group index



<b>AI HG11</b>	0.2177	3.660	0.8967	1.576
<b>BI HG11</b>	0.2986	4.169	0.9312	1.564
<b>CI HG11</b>	0.1957	4.237	1.034	1.748
<b>AI HG13</b>	0.1195	2.750	0.5233	1.182
<b>BI HG13</b>	0.1546	3.571	0.6131	1.617
<b>CI HG13</b>	0.1165	3.256	0.6053	1.479
<b>AI HG17</b>	0.06373	0.9965	0.2996	0.4638
<b>BI HG17</b>	0.07872	1.321	0.2873	0.4673
<b>CI HG17</b>	0.06452	0.9980	0.2647	0.4209
<b>AI HG19</b>	0.04638	0.8052	0.2284	0.3769
<b>BI HG19</b>	0.05853	0.9500	0.2707	0.4466
<b>CI HG19</b>	0.04734	0.9432	0.2711	0.4810

# Add Harmonic load



General Load - Grid\General Load.ElmLod

- Basic Data
- Load Flow**
- VDE/IEC Short-Circuit
- Complete Short-Circuit
- ANSI Short-Circuit
- IEC 61363
- DC Short-Circuit
- RMS-Simulation
- EMT-Simulation
- Hamonics/Power Quality
- Optimal Power Flow
- State Estimation
- Reliability
- Generation Adequacy
- Description

General | **Advanced**

Input Mode

Balanced/Unbalanced | Unbalanced

Operating Point

Current: 0.2070568 kA

Power Factor: 0.8382398 ind.

Voltage: 1. p.u.

Scaling Factor: 1.

Adjusted by Load Scaling      Zone Scaling Factor:

Phase 1

Current: 0.2257 kA

Power Factor: 0.893 ind.

Phase 2

Current: 0.1971 kA

Power Factor: 0.8391 ind.

Phase 3

Current: 0.2013 kA

Power Factor: 0.7638001 ind.

Order	Current (A)			%Fund			Fund (A)		
	A	B	C	A	B	C	A	B	C
3	15.98	1.328	14.04	7.080	0.674	6.975	225.7	197.1	201.3
5	27.63	22.73	33.52	12.242	11.532	16.652			
7	18.85	15	21.37	8.352	7.610	10.616			
9	0.981	1.096	1.315	0.435	0.556	0.653			
11	2.14	4.129	3.382	0.948	2.095	1.680			
13	3.234	1.854	2.777	1.433	0.941	1.380			
17	1.82	2.571	2.688	0.806	1.304	1.335			
19	1.261	0.6135	0.9028	0.559	0.311	0.448			

Harmonic Sources - Equipment Type Library\Harmonic Sources.TypHmccur \*

Basic Data

Description

Name: Harmonic Sources

Type of Harmonic Sources

Balanced, Phase Correct

Unbalanced, Phase Correct

IEC 61000


Harmonics:

	Harmonic Order	la_h/la_1 %	lb_h/lb_1 %	lc_h/lc_1 %
1	3.	7.08	0.674	6.975
2	5.	12.242	11.532	16.652
3	7.	8.352	7.61	10.616
4	9.	0.435	0.556	0.653
5	11.	0.948	2.095	1.68
6	13.	1.433	0.941	1.38
7	17.	0.806	1.304	1.335
▶ 8	19.	0.559	0.311	0.448


# Harmonic Case Study in Power Systems


## Harmonic Load Flow Running

### Cap Bank Step#7



### Cap Bank Step#4







# Harmonic Case Study: Challenge

## Tune Filter





Passive filters are tuned to specific frequencies to reduce current- and voltage-harmonics.



## Detune Filter



Detune filters are tuned to specific frequencies to avoid current- and voltage-harmonics.






# Frequency Response Characteristics

## Devices for Controlling Harmonic Distortion


- Chokes for ASD applications
- Zig-zag transformers
- Passive Filters
- Active filters

## Shunt Passive Filter Configurations




## Effect of Notch Filter on the Frequency Response Characteristics

(a) Typical low voltage filter configuration.





(b) Equivalent circuit of system with filter.




$$h_{notch} = \sqrt{\frac{X_C}{3X_F}}$$

(c) System frequency response ( $Z_1 = 1.0$ ).






Non linear load only



Non linear load  
with Tune filter  
order 5



Non linear load  
with Tune filter  
order 5 and 7

# Harmonic Case Study: Solve by Tune Filter

Change Cap Bank to Tune Filter Order#11

Shunt/Filter - Grid\Shunt/Filter.ElmShnt \*

**Basic Data**

Load Flow  
VDE/IEC Short-Circuit  
Complete Short-Circuit  
ANSI Short-Circuit  
IEC 61363  
DC Short-Circuit  
RMS-Simulation  
EMT-Simulation  
Harmonics/Power Quality  
Optimal Power Flow  
Reliability  
Generation Adequacy  
Description

**General** | Measurement Report | Zero Sequence/Neutral Conductor

Name: Shunt/Filter  
Terminal: Grid\Customer400V\Cub\_2  
Zone: ...  
Area: ...

System Type: AC | Technology: 3PH-D'  
Nominal Voltage: 0.4 kV  
Shunt Type: R-L-C  
Input Mode: Design Parameter

Controller  
Max. No. of Steps: 1 | Max. Rated Reactive Power: 504.2103 kvar  
Act. No. of Step: 1 | Actual Reactive Power: 504.2103 kvar


Design Parameter (per Step)  
Rated Reactive Power, L-C: 504.2103 kvar  
Tuning Order: 10.95436  
Quality Factor (at fr): 0.

Layout Parameter (per Step)  
Capacitance: 3315.784 uF  
Inductance: 0.0254648 mH  
Resistance: 0 Ohm


Design Parameter (per Step)


Rated Reactive Power, L-C: 504.2103 kvar  
Degree: 0.8333476 %  
Quality Factor (at fr): 0.

$$V_C = \frac{V_s}{(1-\%XL)} = \frac{400}{(1-0.0083)} = 403.3 \text{ V}$$




- TR01\_22/0.4kV: Phase Current A/LV-Side in A
- TR01\_22/0.4kV: Phase Current B/LV-Side in A
- TR01\_22/0.4kV: Phase Current C/LV-Side in A
- TR01\_22/0.4kV: Phase Current N/LV-Side in A






Non linear load only





Non linear load  
with Tune filter  
order 5




Non linear load  
with Tune filter  
order 5 and 7


# Harmonic Case Study: Solve by Detune Filter



- Customer400V: CapBank Step#10
- Customer400V: CapBank Step#04
- Customer400V: CapBank Step#05
- Customer400V: CapBank Step#06
- Customer400V: CapBank Step#07
- Customer400V: CapBank Step#08
- Customer400V: CapBank Step#09
- Customer400V: CapBank Step#03



- TR01\_22/0.4kV: Phase Current A/LV-Side in A
- TR01\_22/0.4kV: Phase Current B/LV-Side in A
- TR01\_22/0.4kV: Phase Current C/LV-Side in A
- TR01\_22/0.4kV: Phase Current N/LV-Side in A

The background features a network of glowing purple lines connecting various points. Scattered throughout are numerous white lightbulb icons, some of which are enclosed in white circles. The text 'Thank you for your attention' is written in a large, white, sans-serif font on the right side of the image.

# Thank you for your attention

[wanchalerm.pat@pea.co.th](mailto:wanchalerm.pat@pea.co.th)

[panaya.sud@pea.co.th](mailto:panaya.sud@pea.co.th)